

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

## TEST REPORT

**Client :** Supertuft Pty Ltd  
14 Prince Patrick Street  
Richmond VIC 3121

**Test Number :** 20-000851  
**Issue Date :** 8/05/2020  
**Print Date :** 8/05/2020

**Sample Description** Clients Ref : "Escape Twist/Whenever onto Airstep Supa Blue"  
Cut, twist pile, tufted carpet  
Nominal Composition : 100% Wool  
Nominal Mass per Unit Area/Density : 1630g/m2  
Nominal Thickness : 10mm

### AS/ISO 9239.1-2003

#### Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 07/02/2020

Date Tested 07/05/2020

CHF Value	1	2	3	Mean
Length	8.3	8.8	8.8	8.6 kW/m <sup>2</sup>
Width	8.5	-	-	- kW/m <sup>2</sup>
Smoke Value	1	2	3	Mean
Length	44	41	69	51 %min
Width	32	-	-	- %min

Each specimen was loose laid over Airstep Supa Blue Underlay and then clamped to a 6mm cement sheet.

202732

42537

Page 1 of 1

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing  
- Mechanical Testing  
- Performance & Approvals Testing

: Accreditation No. 983  
: Accreditation No. 985  
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR