

Emission Test Certificate

Tuesday, 10th April, 2012

Supplier: Supertuft Pty Ltd (14 Prince Patrick St, Richmond, VIC 3121)

Sample Description: Escape Velour

Date Tested: March 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Carpet & Rug Institute Green Label Plus test program incorporating ASTM D5116-97 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Carpet & Rug Institute Green Label Plus Specification	Escape Velour
Total Volatile Organic Compound emission rate <500 ug/m ² /hr	Total Volatile Organic Compound emission rate 49 ug/m ² /hr
<p>Emission Rate “Chemicals of Concern”:</p> <p>Acetaldehyde 130 ug/m²/hr</p> <p>Benzene 55 ug/m²/hr</p> <p>Caprolactam 130 ug/m²/hr</p> <p>2-Ethylhexanoic Acid 46 ug/m²/hr</p> <p>Formaldehyde 30 ug/m²/hr</p> <p>1-Methyl-2-Pyrrolidinone 300 ug/m²/hr</p> <p>Naphthalene 8.2 ug/m²/hr</p> <p>Nonanal 24 ug/m²/hr</p> <p>Octanal 13 ug/m²/hr</p> <p>4-Phenylcyclohexene 50 ug/m²/hr</p> <p>Styrene 410 ug/m²/hr</p> <p>Toluene 280 ug/m²/hr</p> <p>Vinyl Acetate 190 ug/m²/hr</p>	<p>Emission Rate:</p> <p>16 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><4 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p> <p><9 ug/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120316