

Emission Test Certificate

Friday June 22nd, 2007

Supplier: Supertuft Pty Ltd (14 Prince Patrick Street, Richmond Victoria 3121)

Sample Description: Escape Twist (100% wool carpet)

Date Tested: June 2007

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Green Building Council of Australia Green Star Office Design (IEQ-13 version 2) and Green Star Office Interiors (IEQ-11 version 1) Specification	Escape Twist
Total Volatile Organic Compound emission rate < 0.5 mg/m ² /hr (24 hours)	Total Volatile Organic Compound emission rate 0.4 mg/m ² /hr (24 hours)
Formaldehyde emission rate < 0.05 mg/m ² /hr (24 hours)	Formaldehyde emission rate <0.02 mg/m ² /hr (24 hours)
4-Phenylcyclohexene emission rate < 0.05 mg/m ² /hr (24 hours)	4-Phenylcyclohexene emission rate <0.02 mg/m ² /hr (24 hours)
Styrene emission rate < 0.4 mg/m ² /hr (24 hours)	Styrene emission rate <0.03 mg/m ² /hr (24 hours)



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant