

Emission Test Certificate

Thursday, 21st June, 2012

Supplier: Supertuft Pty Ltd (14 Prince Patrick St, Richmond VIC 3121)

Sample Description: Whenever

Date Tested: June 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Carpet Institute of Australia Environmental Certification Scheme incorporating ISO 10580: “Resilient, Textile and Laminate Floor Coverings: Evaluation of Volatile Organic Compound Emissions”.

Emission Data:

Carpet Institute of Australia Environmental Certification Scheme Specification	Whenever
Total Volatile Organic Compound emission rate <500 ug/m ² /hr	Total Volatile Organic Compound emission rate 399 ug/m ² /hr
Emission Rate “Chemicals of Concern”: Acetaldehyde <20 ug/m ² /hr Benzene <55 ug/m ² /hr Caprolactam <120 ug/m ² /hr 2-Ethylhexanoic Acid <46 ug/m ² /hr Formaldehyde <10 ug/m ² /hr 1-Methyl-2-Pyrrolidinone <300 ug/m ² /hr Naphthalene <20 ug/m ² /hr Nonanal <24 ug/m ² /hr Octanal <24 ug/m ² /hr 4-Phenylcyclohexene <50 ug/m ² /hr Styrene <410 ug/m ² /hr Toluene <280 ug/m ² /hr Vinyl Acetate <400 ug/m ² /hr 2-Ethyl-1-Hexanol <50 ug/m ² /hr Hydrocarbons (C ₁₀ – C ₁₄) <300 ug/m ² /hr Xylenes <50 ug/m ² /hr Vinyl Cyclohexene <85 ug/m ² /hr	Emission Rate: 5 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr 9 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr 63 ug/m ² /hr <9 ug/m ² /hr <9 ug/m ² /hr 281 ug/m ² /hr 61 ug/m ² /hr 30 ug/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120530